

#### **TODAY'S OBJECTIVES**





- T&D Energy Efficiency Policy Initiative: Advocate
- Advanced Conductors: Explained
- Reduce Line loss and Carbon Emissions: Examples

#### Options to Reduce T&D Losses Include:



Change the way the grid is operated



Improve transformer and other substation equipment efficiency



Change the way the structures hold the conductors



Utilize the advantages of high performance / advanced conductors





#### **BE CONFIDENT: SOLUTIONS ABOUND**






Give guidance to utilities and operators and they will find (many) solutions to improve efficiency within your parameters

#### **Advanced Conductors: Low Sag**





## Why is thermal sag an issue?

Conductor heating causes expansion.
Carrying too much current (causing too much heat) causes the thermal sag to trip and become extremely dangerous.

Advanced Conductors
can deliver up to 2
times the capacity of
traditional conductors
of same diameter
without excessive
thermal sag

### Advanced (low sag) Conductor: Fire Survivability









**Increased Resilience** 



**Increased Reliability** 




Figure 1: Sag comparison at 180°C

6

#### **Advanced Conductors: Resilience**






Post-Tornado:
Oklahoma G&E (2016)
Tornado debris.
Conductor stayed
aloft.
2 bucket trucks and
quick return to service.

Resilient: Rapid return to service

### **Advanced Conductors: Give Operators More Options**



#### **Advanced Conductors: Efficiency**






- Most carry more aluminum for the same diameter versus traditional ACSR
- This reduces resistance for the same current flow
- Lower Resistance = Lower Losses (@ same current)
- Up to 40% lower losses than traditional conductor of the same diameter (efficiency varies among advanced conductors)

#### Carbon Reductions (@ 30% Reduction Target)





## Advanced Conductor: Get MORE from existing ROW



- Advanced Conductors can enable more performance on existing ROW. They can provide:
  - More power flow to relieve congestion, improve reliability, and increase resiliency
  - Reduce line loss
  - Line-for-line reconductoring using <u>existing structures</u> (weight matters)
  - 20%-40% lower costs than traditional rebuild solution

#### CASE STUDIES:

- AEP
- SCE
- Xcel Energy







#### **Policy Considerations**





- T&D Energy Efficiency Policy Guidance:
  - Every T&D project should have EE savings included in the Cost/Benefit analysis
  - EE savings should be fully inclusive
    - energy/fuel savings
    - CO<sub>2</sub> savings
    - SOx/NOx savings
    - water reduction savings
    - other (e.g. low-income emission reduction impacts)
  - Follow the approved guidance for end-use EE projects
  - Incentives: Register T&D EE projects? Allow CO<sub>2</sub> counting?



# BE BOLD TAKE ACTION

- "Harvest" energy and carbon savings from the overlooked T&D system
- Every utility investment in the T&D system has guidance to increase energy efficiency
- Recognize the magnitude of these savings and benefits
- T&D investments are made every year. Make them count toward a more efficient electric delivery system
- Give guidance to utilities and operators and they WILL FIND SOLUTIONS within the parameters you describe

# Thank You CTC GLOBAL Questions **CTC Global Corporation** 2026 McGaw Avenue Irvine, CA 92614 USA +1(949)428-8500 WWW.ctcglobal.com

## Link to Navigant Article



#### **RESOURCE:**

https://www.navigantresearch.com/news-and-views/advanced-conductors-are-changing-the-economics-of-new-transmission-line-buildsand-existing-line-upgr